



PRODUCT CERTIFICATION SCHEME SDP11-02

Certificate number: IFCC 1542

This is a product certificate to certify that

A1 Shutters Limited

Raikes Lane Industrial Estate,
Raikes Lane,
Bolton BL3 2NH

Who fabricate the following product:

Product Type:	Active Fire Curtain Barrier Assembly
Product Name:	Flameshield Fire Curtain
Construction Type:	Single
Fabric Type:	4415-2-SP
Product Standard:	BS 8524-1:2013
Fire Resistance:	120 minutes Integrity (E) and 60 minutes Radiation (EW) performance to EN 1634-1:2014+A1:2018 (EN 1363-1:2012 & EN 1363-2:1999)
Classification:	E15, E20, E30, E45, E60, E90 & E120 plus EW60 to EN 13501-2:2016

*have satisfied the requirements of scheme SDP11-2 this includes evaluation of the product performance in accordance with **BS 8524-1:2013**, inspection of the Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application are detailed in the Schedule referenced below.*



Schedule ref: FSA_20356_01
First Issued: 27 February 2020
Valid to: 26 February 2025
Issue No: 1

Ian Woodhouse
Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire, HP27 9AH, UK,
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.