



PENETRATION & LINEAR GAP SEALS SCHEME SDP13

Certificate number: IFCC 1058/14

This is a product certificate to certify that

Rockwool Ltd

Pencoed
Bridgend
CF35 6NY
Telephone no. +44 (0) 1656 862 621

Who manufacture the following system:

Rockwool Firepro High Expansion Intumescent Sealant

have satisfied the requirements of the above scheme. This includes the testing of products to **EN1366-3**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve up to 4 hours fire resistance are detailed in the schedule referenced below.



Schedule number: IFCC1058/S14
Initial registration: 02 August 2013
Valid to: 01 August 2018
Issue status: 1



175

Bob Williams
Director of Certification

Peter E Jackman
Technical Director

IFC Certification Ltd
20 Park Street, Princes Risborough, Buckinghamshire. England HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.