



## **FIRE RESISTANT TIMBER FIRE DOORS**

***Certificate number: IFCC 1079***

This is a product certificate to certify that

***Bukshaisha for Aluminium & Carpentry***

Doha – Qatar Industrial Area  
St. No. 37, Gate No. 22  
PO Box No.16600, Qatar  
Tel no.: +974 44602625  
Email: bacqatar1@hotmail.com

Who fabricate the following fire doors:

**Kingsa FD30 Kingsa FD60 Kingsa FD90 Kingsa FD120  
Halspan FD30 Halspan FD60 Halspan FD90 Halspan FD120**

have satisfied the requirements of the SDP01 Timber Fire Door scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below.

Schedule ref: KS01, KS02, KS03, KS04, HS01, HS02, HS03, HS04, HS05, HS06



First Issued: 21 March 2014  
Revised: 23 January 2017  
Reissued: 25 April 2019  
Valid to: 20 March 2024  
Issue No: 5



175

**Ian Woodhouse**  
Certification Director

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH  
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.