



## **FIRE RESISTANT STEEL DOOR**

***Certificate number: IFCC 1081***

This certificate certifies that the product below  
manufactured by

***Fitzpatrick s.a.l.***

Meker Building – Industrial City  
Nahr El Mott  
Beirut  
Tel no.: +961 1 901888

### ***Fitzpatrick Steel Lath Roller Shutter***

Satisfy the requirements of the SDP02 Metal Fire Door scheme. This includes the testing of products to **BS476-22: 1987**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 240 minutes integrity** are detailed in the schedules referenced below.

Schedule ref: IFCC 1081/S01



First Issued: 9 April 2014  
Re-issued 30 January 2017  
Valid to: 8 April 2019  
Issue No: 2

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

**Ian Woodhouse**  
Director of Certification

---

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH  
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.