



FIRE RESISTANT STEEL & S/S GLAZED FIRE DOORS & FIXED SCREEN

Certificate number: IFCC 1087

This is a product certificate to certify that

Indigatech FZ LLC

PO BOX 6695
Ras Al Khaimah
UAE

Telephone no. 0097172434511

Who fabricate the following:

Forster Fuego Light Glazed Steel Doorsets (EI 30, EI 60, EI 90)
Forster Fuego Light Glazed Steel Screens (EI 30, EI 60)
Forster Thermfix Vario Screens (EI 90)

have satisfied the requirements of the above schemes. This includes the testing of products to **BS476: Part 22; EN1634-1 and EN1364-1** (as appropriate), the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30, 60 and 90 minutes integrity and insulation** are detailed in the schedules referenced below.

Schedule ref: IFCC/1087/S01 & S02



First Issued: 16 June 2014
Revised: 21 January 2016
Valid to: 15 June 2019
Issue No: 4



175

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.