



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC 1117

This is a product certificate to certify that

Integrated Wood Industries

PO Box 299, Aljiza 16010

Jordan

Tel. no. +962 6 471 1881

Who fabricate the following fire doors:

<i>FireBan FD30</i>	<i>FireBan FD60</i>	<i>FireBan FD90</i>	<i>FireBan FD120</i>
<i>Halspan FD30</i>	<i>Halspan FD60</i>	<i>Halspan FD90</i>	<i>Halspan FD120</i>
<i>Strebord FD30</i>	<i>Strebord FD60</i>	<i>Strebord FD90</i>	
<i>Warm Springs FD60</i>	<i>Warm Springs FD90</i>	<i>Warm Springs FD120</i>	

have satisfied the requirements of the SDP01 Timber Fire Door scheme. This includes the testing of products to **BS476: Part 22**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve **30 minutes to 120 minutes integrity** is detailed in the schedule referenced below.

Schedule ref: GTL.S03, GTL.S04, HS01-HS06,
SS01, SS02, SS03, WS02



First Issued: 9 December 2014

Revised: 15 January 2018

Valid to: 8 December 2019

Issue No: 3



175

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. HP27 9AH, UK
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.