



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC1142

This is a product certificate to certify that

Woodworks

Shahaniya Industrial Area
Al Sadd Kia Building
P.O. Box: 2754
Doha
Qatar
Tel: +974 4490 1477

Who fabricate the following fire doors:

Halspan FD30	Halspan FD60	Halspan FD90	Halspan FD120
FireBan FD30	FireBan FD60	FireBan FD90	FireBan FD120

have satisfied the requirements of the above scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below.

Schedule ref: HS01, HS02, HS03, HS04, HS05, HS06, GTLS02



First Issued: 9 April 2015
Valid to: 8 April 2020
Issue No: 1

A handwritten signature in black ink, appearing to read 'Bob Williams'.

Bob Williams
Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. HP27 9AH, UK
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.