



FIRE RESISTING PARTITIONS AND INTERNAL GLAZED SCREENS

Certificate number: IFCC1151

This is a product certificate to certify that

TecFire Middle East FzE

Dubai Silicon Oasis
D-Wing G04-2
Dubai 341012
Telephone no. :- +971 437 24480

Who fabricate the following fire rated glazed partition:

Steelfire S50-70 Fixed Partitions

have satisfied the requirements of the above scheme, SDP21 (Partitions). This includes the testing of products to **EN1363-1, EN1364-1, & NFPA 251-2006, ANSI/UL 263-2003 and ASTM E119-12**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specifications to achieve **EI60 and 60 minutes fire resistance** are detailed in the test reports referenced below.



Test reports: 14-7541-36 P1
14-7541-36 P2
13-7541-3429

First Issued: 29 June 2015
Valid to: 27 October 2020
Issue No: 1



175

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. HP27 9AH, UK
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.