



# FIRE RESISTING PARTITIONS AND INTERNAL GLAZED SCREENS

***Certificate number: IFCC1217***

This is a product certificate to certify that

***TecFire Middle East FzE***

Dubai Silicon Oasis  
A-Wing G06-07  
Dubai 341012  
Telephone no. :- +971 437 24480

Who fabricate the following fire rated glazed partition:

**STB80 Frameless Butt Jointed System**

have satisfied the requirements of the above scheme, SDP21 (Partitions). This includes the testing of products to **EN1364-1**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specifications to achieve **EI60** are detailed in the test reports referenced below.



Test reports: 15-10463-2625 P1  
15-10463-2625-P2

First Issued: 15 February 2016  
Revised 15 February 2017  
Valid to: 14 February 2021  
Issue No: 4



175

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse  
Director of Certification

---

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. HP27 9AH, UK  
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.