



PENETRATION & LINEAR GAP SEALS SCHEME SDP13

Certificate number: IFCC1232

This is a product certificate to certify that

***Pre-Formed Components Ltd trading as
PFC COROFIL &
PFC Technical Services Ltd
In partnership with Corofil***

Units 3 & 4
King George Trading Estate
Davis Road
Surrey
KT9 1TT
Telephone no. +44 (0) 208 391 0533
www.pfc-corofil.com

Who manufacture the following ***Corofil CF Fire Protection System:***

have satisfied the requirements of the above scheme SDP 13. This includes the testing of products to BS 476: Part 8 and BS 476: Part 21, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specifications to achieve up to **120 minutes Integrity, Stability & Insulation** are detailed in the test & the assessment reports referenced below.

Test report: TE 5487 & CC 93722D



First Issued: 09 May 2016
Valid to: 08 May 2021
Issue No: 1

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. HP27 9AH, UK
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.