



# FIRE RESISTANT TIMBER FIRE DOORS

**Certificate number: IFCC1265**

This is a product certificate to certify that

## **David Smith St Ives Limited**

Marley Road  
St Ives  
Huntingdon  
Cambridgeshire  
PE27 3EX  
01480 309900  
doors@davidsmith.co.uk

Who fabricate the following fire doors and doorsets:

**DSF (FD30, FD60), DSP (FD30, FD60), DST (FD30, FD60), DSTm (FD30, FD60), DSA (FD30, FD60), DSM (FD90, FD120) and DSXL (FD30, FD60)  
Flush Doors**

have satisfied the requirements of the SDP01 Fire Resistant Timber & Wood Based Door Scheme. This includes the testing of products to **BS476: Part 22**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below.

Schedule refs: IFCC1265-DSF01/IFCC1265-DSP02/IFCC1265-DST03/IFCC1265-DSTm04/IFCC1265-DSA05/IFCC1265-DSM06 & IFCC1265-DSXL07



First Issued: 25 October 2016  
Valid to: 24 October 2021  
Issue No: 1

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

**Ian Woodhouse**  
Director of Certification



**175**

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. HP27 9AH, UK  
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.