



PRODUCT CERTIFICATION SCHEME SDP11-02

Certificate number: IFCC/1280

This is a product certificate to certify that

Coopers Fire Ltd.

Edward House, Penner Road, Havant,
Hampshire, PO9 1QZ, United Kingdom

Who fabricate the following product:

Product:	Vii®Fire A1 - Active Fire Curtain Barrier Assembly as a 'single' construction using EFP™ A1 fabric
Product Standard:	BS 8524-1:2013
Fire Resistance:	120 minutes Integrity and 30 minutes Radiation performance to BS EN 1634-1:2014 (BS EN 1363-1:2016 & BS EN 1363-2:1999)
Classification:	E15, E20, E30, E45, E60, E90, E120 EW20 & EW30 to BS EN 13501-2:2016
Smoke Leakage:	3m ³ /m/h to BS EN 1634-3:2004

*have satisfied the requirements of IFCC scheme SDP11-2 Retractable Fabric Fire Resisting Fabric Curtains Enhanced Performance this includes evaluation of the product performance in accordance with **BS 8524-1:2013**, inspection of the Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application are detailed in the Schedule referenced below.*



Schedule ref: IFCC/1280 S01
First Issued: 25 January 2017
Revised: 01 Aug 2017
Valid to: 24 January 2022
Issue No: 2



175

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire, HP27 9AH, UK,
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.