



FIRE RESISTING ALUMINIUM DOORS

Certificate number: IFCC1282

This is a product certificate to certify that

TecFire Middle East FzE

Dubai Silicon Oasis

A-Wing G06-07

Dubai 341012

Telephone no. :- +971 437 24480

Who fabricate the following fire rated glazed partition:

Alufire AS85 Double Leaf Door

have satisfied the requirements of the above scheme, SDP 02 (Doors). This includes the testing of products to **EN1634-1**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specifications to achieve **EI₂60 Integrity & Insulation** are detailed in the test reports referenced below.



Test reports: 16/10463-1545

First Issued: 30 January 2017

Revised 17 February 2017

Valid to: 29 January 2022

Issue No: 2



175

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. HP27 9AH, UK
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.