



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC1345

This is a product certificate to certify that

Elegant House

P.O. Box 936,
Sohar 311
Oman
Tel: 0096 826755992

Who fabricate the following fire doors:

Kingsa FD30 Kingsa FD60 Kingsa FD90 Kingsa FD120
FireBan FD30 FireBan FD60 FireBan FD90 FireBan FD120

have satisfied the requirements of the SDP01 Timber Fire Doors scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below.

Schedule ref: KS01, 02, 03 & 04 + GTL S03 & 04



First Issued: 19 December 2017
Valid to: 18 December 2022
Issue No: 1



175

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. HP27 9AH, UK
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.