



## FIRE RATED DOOR LININGS

***Certificate number: IFCC 1348***

This is a product certificate to certify that

***Tayco Building Products Ltd***

Unit 17, Ryelands Farm Industrial Estate  
Bagley Road  
Rockwell Green  
Wellington  
Somerset  
TA21 9PZ  
Telephone: 01823 667038

Who manufacture fire and non fire rated door linings:

have satisfied the requirements of the **IFCC SDP01** Fire Resistant Timber and Wood Based Door and Frame scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits for the manufacture of FD30 and FD60 door linings. The frame specification and field of application for the **30 minutes to 60 minutes integrity** are as detailed in the relevant door manufacturers assessments and field of application reports.



First Issued: 12 January 2018  
Valid to: 11 January 2023  
Issue No: 1

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse  
Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com) Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.