



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC 1354

This is a product certificate to certify that

Modern Arz Carpentry

P O Box 23457, Doha, Qatar

info@alarz.work

Tel: 00974 4444 2103

Fax: 00974 4444 2102

Who fabricate the following fire doors:

Halspan FD30 Halspan FD60 Halspan FD90 Halspan FD120

FireBan FD30 FireBan FD60 FireBan FD90 FireBan FD120

have satisfied the requirements of the SDP01 Timber Fire Doors scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below.

Schedule ref: HS01 - HS06 & GTLS03 – GTLS04



First Issued: 20 December 2017

Revised: 18 April 2018

Valid to: 19 December 2022

Issue No: 3

Ian Woodhouse
Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. HP27 9AH, UK
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.