



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC1365

This is a product certificate to certify that

Sekoya Chobe Atlas

No315, 9th Aboureihan,
Mourchekhort Industrial Zone,
Isfahan
Iran
Tel: +98 3145642523

FireBAN FD30

FireBAN FD60

FireBAN FD90

FireBAN FD120

have satisfied the requirements of the SDP01 Timber Fire Door scheme. This includes the testing of products to **BS476: Part 22**, the inspection of their Factory Production Control continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes** integrity are detailed in the schedules referenced below.



Schedule ref: GTL/S03 & S04

First Issued: 06 February 2018

Reissued: 03 January 2020

Valid to: 05 February 2023

Issue No: 2



175

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.