



# FIRE RESISTANT TIMBER FIRE DOORS

**Certificate number: IFCC 1369**

This is a product certificate to certify that

## ***One for Aluminium & Wood - ALUONE***

P.O. Box 201939, Doha Qatar  
(Industrial Area Gate 177, Street 50),  
Doha  
Qatar

Tel: 00974 5556 0216

Who fabricate the following fire doors:

<b>Halspan FD30</b>	<b>Halspan FD60</b>	<b>Halspan FD90</b>	<b>Halspan FD120</b>
<b>FireBan FD30</b>	<b>FireBan FD60</b>	<b>FireBan FD90</b>	<b>FireBan FD120</b>

have satisfied the requirements of the SDP01 Timber Fire Doors scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below.

Schedule ref: HS01 - HS06 & GTLS03 – GTLS04



First Issued: 16 March 2018  
Valid to: 15 March 2023  
Issue No: 1

Ian Woodhouse  
Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. HP27 9AH, UK  
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.