



FIRE RESISTANT STEEL DOORS

Certificate number: IFCC1379

This is a product certificate to certify that

TecFire Middle East FzE

Dubai Silicon Oasis
B-Wing 507-508
Dubai 341012
Telephone no: +971 437 24480

Who fabricate the following fire rated double leaf doorset:

Steelfire STB80 Double Leaf Door

have satisfied the requirements of the **IFCC** scheme, SDP 02 (Doors). This includes the testing of products to **EN1634 Part 1 & EN1363 Part 1**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specifications to achieve **EI260 (Integrity & Insulation)** are detailed in the test reports referenced below.



Test reports: 17/14483-1117 Part 1
17/14483-1117 Part 2

First Issued: 8 May 2018
Valid to: 7 May 2023
Issue No: 1



175

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. HP27 9AH, UK
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.