



FIRE RESISTANT METAL BASED DOOR SCHEME

Certificate number: IFCC 1397

This is a product certificate to certify that

Neron Metal Industry AS

Organize Sanayi Bolgesi 30,
Cabbe No. 11 Melikgazi Kayseri
Turkey

Tel: 0090 352 5034334

Who fabricate the following steel fire doorsets:

Single Leaf Fire Resistant Steel Door E120 & EI90

have satisfied the requirements of the SDP02 Fire resistant metal based door scheme. This includes the testing of products to **BS EN 1634-1: 2014 and BS EN 1363-1: 2012** the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** refs: IFCC1397/SO1



Initial certification: 06 June 2018
Valid to: 05 June 2023
Issue status: Issue 1

Ian Woodhouse
Director of Certification



175

IFC Certification Ltd
20 Park Street, Princes Risborough, Buckinghamshire. England HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.