

Steeltech for Trading and Contracting W.L.L

Product range

"Techno Safe" Non-Coated Fire Rated Uninsulated Duct System

240 mins Stability & 170 mins Integrity
(as defined by BS476-24:1987)

Manufacturing location:

New Industrial Area, Pink Zone, Street M & 12 Intersection, PO Box 203162,
Qatar

The application of this product should be carried out following the
manufacturer's instructions and according to the following documents:

Test Report No. 18/17543-1935-1
Assessment Report No. 19/17543-130

This schedule must be read in conjunction with test report 18/17543-1935-1 and assessment report 19/17543-130 and all aspects of the specification and limitations defined therein must be satisfied. Failure to comply with all specifications will invalidate the approval, and may jeopardise the fire performance.



Director of Certification
Ian Woodhouse

Date: 29 April 2019

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.

©IFC Certification Ltd