



FIRE RATED DUCTWORK & COMPONENTS SCHEME

Certificate number: IFCC1488

This is a product certificate to certify that

Steeltech for Trading and Contracting W.L.L

New Industrial Area
Pink Zone
Street M & 12 Intersection
PO BOX 203162 - Qatar
Telephone no. (+974) 4444 8969

Who supply the following products

Techno Safe Non-Coated Fire Rated Duct System

has satisfied the requirements of the SDP 26-1 fire resisting ducts (including smoke extraction) and components scheme. This includes the testing of products to **BS 476: Part 24: 1987**. The inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve a minimum of **240 minutes stability and 170 minutes integrity** are detailed in the schedule referenced below.

Schedules ref: IFCC1488/S01



First Issued: 29 April 2019
Valid to: 28 April 2024
Issue No: 1

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.