

I Tech Building Solutions WLL ***CERTIFICATION SCHEDULE***

for

I Tech Building Solutions, Single Acting, Uninsulated, Door Assemblies including Leaves with a Mineral Rock Fibre Core or Honeycomb Core

This Schedule should be read in conjunction with Certificate No. **IFCC 1415**. The scope of approval herein is based upon the Field of Application given in IFC Report PAR/16522/01 (Mineral Core) and PAR/16522/02 (Honeycomb Core) to BS476: Part 22: 1987 for 60 to 240 minutes integrity performance. As such, the stated reports should be consulted should clarification of any detail be required.

1. The following configurations are approved:

- Single and Double leaf, latched, single-action doors, opening towards and away from the heating conditions

2. The following options are approved for the above configurations

- i) Vision Panels
- ii) Size variations with regards to 60 to 240 minutes integrity performance all as specified in IFC report PAR/16522/01 & PAR/16522/02.



Ian Woodhouse
Director, IFC Certification



Issued 25 September 2018

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.

©IFC Certification Ltd