



FIRE RATED DUCTWORK & COMPONENTS SCHEME

Certificate number: IFCC 1327

This is a product certificate to certify that

Promat Fire Protection LLC

Plot Number 597-921,
Dubai Investment Park 2,
PO BOX 123945,
Dubai

Tele no. 0097148853070

Who fabricate the following product

Promat[®]-WRAP Fabric for use in Fire-resisting Ductwork Systems

have satisfied the requirements of the SDP 26-1 Fire Resisting Ducts (including Smoke Extraction) & Components scheme Appendix D. This includes the testing of products to **BS476: Part 24**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve **1 hr, 2 hrs and 4 hrs stability, integrity & insulation** are detailed in the schedules referenced below.



Schedules ref: IFCC1327/S01

First Issued: 17 October 2017

Valid to: 16 October 2022

Issue No: 1

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.