



FIRE RESISTANT TIMBER FIRE DOOR

Certificate number: IFCC 1085

This is a product certificate to certify that

Target LLC

P O Box 574
Ruwi
Sultanate of Oman
Postal Code 112

Who fabricate the following fire doors

**Own Design Target FD30 & FD60
Halspan FD30 Halspan FD60 Halspan FD90 Halspan FD120**

have satisfied the requirements of the SDP01 scheme. This includes the testing of products to **BS476: Part 22**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes and 120 minutes integrity** are detailed in the schedule referenced below.



Schedules ref: IFCC1085/T01, T02, HS01,
HS02, HS03, HS04, HS05, HS06, HS07

First Issued: 21 May 2014
Revised 22 December 2015
Valid to: 20 May 2019
Issue No: 2



175

A handwritten signature in black ink, appearing to read 'Iain Macalister'.

Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.