



## **FIRE RATED DUCTS SCHEME SDP26/2**

***Certificate number: IFCC 1062***

This is a product certificate to certify that

### ***Firemac FM Blue Ltd***

Mill Walk Business Park  
Tantallon Road  
North Berwick  
East Lothian EH39 5NB  
Telephone no. +44 (0) 16 2089 2202

Who supply the following products

#### **FM Blue Service Enclosure System**

have satisfied the requirements of the above scheme. This includes the testing of products to **BS476: Part 20: 1987 (ISO 834: 1985)**. The inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve up to **240 minutes integrity** with variable insulation are detailed in the schedule referenced below.

Schedules ref: IFCC1062/S01



First Issued: 07 January 2014

Valid to: 06 January 2019

Issue No: 1



175

A handwritten signature in black ink, appearing to read 'Bob Williams'.

**Bob Williams**  
Director of Certification

A handwritten signature in black ink, appearing to read 'Peter Jackman'.

**Peter Jackman**  
Technical Director

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH  
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.