



FIRE RESISTANT CEILING SCHEME SDP21

Certificate number: IFCC1064

This is a product certificate to certify that

Firemac FM Blue Ltd

Mill Walk Business Park
Tantallon Road
North Berwick
East Lothian EH39 5NB
Telephone no. +44 (0) 16 2089 2202

Who supply the following systems

FM Blue Ceiling Membrane Systems

have satisfied the requirements of the above scheme. This includes the testing of products to **BS476: Part 22: 1987 (ISO 834: 1985)**. The inspection of their Factory Production Control and continuing surveillance audits including testing of samples of products taken from production. The product specification and field of application to achieve where applicable up to **240 minutes stability, Integrity and up to 120 minutes Insulation** as a ceiling from fire above and below are detailed in the schedule referenced below.



Schedules ref: IFCC1064/S01
First Issued: 07 January 2014
Valid to: 06 January 2019
Issue No: 1



175

A handwritten signature in black ink, appearing to read 'B. Williams'.

Bob Williams
Director of Certification

A handwritten signature in black ink, appearing to read 'P. E. Jackman'.

Peter Jackman
Technical Director

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.