



PRODUCT CERTIFICATION SCHEME SDP11-01

Certificate number: IFCC1120

This is a product certificate to certify that

Coopers Fire Ltd

Edward House
Penner Road
Havant
Hampshire
PO9 1QZ
UK

Who fabricate the following product:

FireMaster® A1 Fire Barrier Uninsulated Drop Curtain

have satisfied the requirements of scheme SDP11-1 this includes the initial type testing of products to **BS EN 1634-1**, evaluation of the product performance, inspection of the Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve **240 minutes integrity** to **BS EN 1634-1** are detailed in the Schedule referenced below.



Schedule ref: IFCC1 20/S01
First Issued: 8 January 2015
Valid to: 7 January 2020
Issue No: 1



175

A handwritten signature in black ink, appearing to read 'Bob Williams'.

Bob Williams
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: + (0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.