



## **FIRE RESISTING PARTITION SYSTEM**

***Certificate number: IFCC 1337***

This is a product certificate to certify that

***Culimeta-Saveguard Ltd,***

*Tower Mill,*

*Park Road,*

*Dukinfield, SK16 5LP*

Phone: 0161 344 2484

Who fabricate the following:

***Firehalt 90 / 60 Fire Barrier System***

have successfully completed the requirements of the SDP 21 (Partitions) scheme. This includes the fire testing of products to **BS 476: Part 22: 1987** the inspection of their Factory Production Control and continuing surveillance assessments and testing of samples of products taken from production. The product specification and field of application to achieve **90 minutes integrity / 60 minutes insulation** is detailed in the accompanying schedule:



Schedule number: IFCC 1337/S01  
Initial certification: 02 November 2017  
Revised: 01 June 2022  
Valid to: 01 November 2022  
Issue No.: 2



175

A handwritten signature in black ink, which appears to read 'Ian Woodhouse'.

Ian Woodhouse  
Director of Certification

---

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH  
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.