



# CERTIFICATE OF CONSTANCY OF PERFORMANCE

## 1720-CPR-0237

In compliance with Statutory Instruments 2019 No.465 of the United Kingdom Houses of Parliament 5th March 2019 (The Construction Products (Amendment etc.) (EU Exit) Regulations 2019), this certificate applies to the construction product:

### Glazed Single Lid Smoke Hatch

**Test Report Refs: Annex C, D and E – 8P00573-01, Annex F 8P00573-02Rev 1, Annex G – 8P00573-03**

The ventilator is a roof mounted Smoke and Heat exhaust ventilator. The geometric dimensions of the ventilator are (width x length) 1200 x 2100mm and the dimensions of the opening area applied for snow load were 1110 x 2010mm. The opening mechanism consisted of chain motor designated WMU 895-1 EN 10000 0104.

**Glazed Single Lid Smoke Hatch is produced by**

**Lareine Engineering Limited, Unit One, 28 Firth Road, Houstoun Industrial Estate, Livingston, West Lothian, EH54 5DJ**

**In the manufacturing plant: Lareine Engineering Limited, Armadale Industrial Estate, Armadale, West Lothian, EH48 2ND.**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard.

### BS EN 12101-2:2003

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annexes, C, D, E, F, G & ZA, and Clause 7.5.2.1 of the standard:

**BS EN 12101-2:2003**, under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the Glazed Single Lid Smoke Hatch vent compliant as follows:

|                         |                     |                  |                  |                    |                 |                      |
|-------------------------|---------------------|------------------|------------------|--------------------|-----------------|----------------------|
| Annex B<br>(AFA)<br>NPD | Annex C<br>Re A 500 | Annex D<br>SL500 | Annex E<br>T(-5) | Annex F<br>WL 1500 | Annex G<br>B300 | Clause 7.5.2.1<br>A1 |
|-------------------------|---------------------|------------------|------------------|--------------------|-----------------|----------------------|

This certificate was first issued on 17<sup>th</sup> June 2021 and will remain valid as long as neither the designated standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are not modified significantly unless suspended or withdrawn by the approved product certification body.



Princes Risborough, UK

Ian Woodhouse  
Director of Certification

**IFC Certification Ltd**  
**UK Approved Body No. 1720**

20 Park Street, Princes Risborough, Buckinghamshire, HP27 9AH, UK  
Tel: +44(0) 1844 275500, Fax: +44(0) 1844 274002, E-mail: info@ifccertification.com  
Registered No: 4777898 England  
©IFC Certification Ltd 2021