



CERTIFICATE OF CONSTANCY OF PERFORMANCE

1720-CPR-0241

In compliance with Statutory Instruments 2019 No.465 of the United Kingdom Houses of Parliament 5th March 2019 (The Construction Products (Amendment etc.) (EU Exit) Regulations 2019), this certificate applies to the construction product:

Power Supplies

Power supplies (utilising back up batteries) for integrated control panels for use in smoke and heat control systems.

Product name:

WSC 204 KP

Performances: Class A, Environmental class 1

placed on the market under the name or trademark of:

WindowMaster A/S
Skelstedet 13
DK-2950 Vedbæk Denmark

and produced in the manufacturing plant:

WindowMaster Industries GmbH
Hellerweg 180
DE-32052 Herford Germany

The controller was tested in accordance with the requirements of EN 12101-10:2005

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard.

EN 12101-10:2005

Under the system level applied it is considered that the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 03 November 2021 and will remain valid as long as neither the designated standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are not modified significantly unless suspended or withdrawn by the approved product certification body. .

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification

Princes Risborough, UK

IFC Certification Ltd
UK Approved Body No. 1720

20 Park Street, Princes Risborough, Buckinghamshire, HP27 9AH, UK
Tel: +44(0) 1844 275500, Fax: +44(0) 1844 274002, E-mail: info@ifccertification.com
Registered No: 4777898 England
©IFC Certification Ltd 2021