



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC 1034

Certificate only valid if verified on website - www.ifccertification.com

This is a product certificate to certify that

Bonfire Shield

PO Box 3551

Doha

Qatar

Telephone no. +974 4412 8211

Who fabricate the following timber fire doors and or doorsets:

Bonfire BSM FD30, BSM FD60, BSM FD90, BSM FD120

have satisfied the requirements of the SDP01 Timber Fire Door scheme. This includes the testing of products to **BS476: Part 22**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30, 60, 90 and 120 minutes integrity** are detailed in the schedules referenced below.

Schedules ref: IFCC 1034 / S01, S02, S03, S04, S05



First Issued: 23 September 2013

Revised 25 November 2020

Valid to: 22 September 2023

Issue No: 5

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.