



PENETRATION & LINEAR GAP SEALS SCHEME SDP13

Certificate number: IFCC 1669

Certificate only valid if verified on website - www.ifccertification.com

This is a product certificate to certify that

Pre-Formed Components Ltd trading as

PFC COROFIL

Units 3 & 4

King George Trading Estate

Davis Road

Surrey

KT9 1TT

Telephone no. +44 (0) 208 391 0533

www.pfc-corofil.com

Which manufacture the following systems:

CFSC PFC Corofil Fire Stop Compound

have satisfied the requirements of the above scheme. This includes the testing of products to BSEN 1366-3: 2009 and BSEN 1363-1: 1999, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specifications to achieve up to 240 minutes Fire Resistance (Integrity) are given in the following report detailed below:

Test Report: BMT/FEI/F14015

First Issued: 5th October 2021

Valid to: 4th October 2026

Issue status: 1



175

A handwritten signature in black ink, which appears to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification

IFC Certification Ltd

20 Park Street, Princes Risborough, Buckinghamshire. England HP27 9AH

Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com

Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.