



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC1295

This is a product certificate to certify that

Al Rawahi International Co LLC

P.O Box 491,
Ruwi 112
Sultanate of Oman
Tel: 00968 24490018

**FireBAN FD30 FireBAN FD60 FireBAN FD90 FireBAN FD120
Moralt FD30 Moralt FD60 Moralt FD90**

have satisfied the requirements of the SDP01 Timber Fire Door scheme. This includes the testing of products to **BS476: Part 22**, the inspection of their Factory Production Control continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes** integrity are detailed in the schedules referenced below.



Schedule ref: GTL/S03 & S04
IFCC1295/S01
First Issued: 13 April 2017
Revised 18 August 2017
Reissued: 26 October 2022
Valid to: 12 April 2027
Issue No: 3



175

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

**Ian Woodhouse
Director of Certification**

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.