



PRODUCT CERTIFICATION SCHEME SDP11-02

Certificate number: IFCC 1656

This is a product certificate to certify that

K & D Systems Holdings Limited

2 Charles Street
Sunderland
Tyne & Wear SR6 0AN

Who fabricate the following product:

Product Type:	Active Fire Curtain Barrier Assembly
Product Name:	Ultimate Fire & Smoke Curtain
Construction Type:	Double-layered fabric Single
Fabric Types:	05258(TG415)-2SP-(HP) & 4415-2-SP(HP)
Product Standard:	BS 8524-1:2013
Fire Resistance:	180 minutes Integrity (E) and 60 minutes Radiation (EW) performance to EN 1634-1:2014+A1:2018 (EN 1363-1:2012 & EN 1363-2:1999)
Classification:	E15, E20, E30, E45, E60, E90, E120 & E180 EW60 to EN 13501-2:2016
Smoke Leakage:	2.99m ³ /m/h to BS EN 1634 3:2004

*have satisfied the requirements of scheme SDP11-2 this includes evaluation of the product performance in accordance with **BS 8524-1:2013**, inspection of the Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application are detailed in the Schedule referenced below.*



Schedule ref: FSA_21853_01
First Issued: 03 August 2021
Valid to: 02 August 2026
Issue No: 1

Ian Woodhouse
Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire, HP27 9AH, UK,
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.