



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC 1616

Certificate only valid if verified on website - www.ifccertification.com

This is a product certificate to certify that

Global Industrial Services LLC

PO BOX 2271, PC 133

Al Khuwair

Sultanate of Oman

Tel. +968 24121855

Who fabricate the following timber fire doors and or doorsets:

Halspan FD30	Halspan FD60	Halspan FD90	Halspan FD120
FireBan FD30	FireBan FD60	FireBan FD90	FireBan FD120
Kingsa FD30	Kingsa FD60	Kingsa FD90	Kingsa FD120
Strebord FD30	Strebord FD60	Ramkor FD90	Ramkor FD120

have satisfied the requirements of the SDP01 Timber Fire Doors scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below.

Schedule refs: HS01 - HS06, GTLS03 - GTLS04, KS01 - KS04, SS01, SS02, RA01, RA02



First Issued: 15 December 2020

Valid to: 14 December 2025

Issue No: 1

Ian Woodhouse

Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. HP27 9AH, UK
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.