



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: FRTD 427

Certificate only valid if verified on website - www.ifccertification.com

This is a product certificate to certify that

Falcon Panel Products Ltd

Clock House
Station Approach
Shepperton
Middlesex
TW17 8AN, UK
Tel: +44 (0) 1932 256580

Who manufacture door blanks used for the fabrication of the following fire doors & doorsets:

**FD30 Strebord 44[®] & FD60 Strebord 54[®],
Stredor 44, Stredor 54, FD30 Lux &
FD60, FD90 & FD120 Warm Springs Composite Products**

have satisfied the requirements of IFCC SDP 01 Fire Resistant Timber & Wood Based Door Scheme. This includes the testing of products to **BS476: Part 22**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specifications and field of application reports to achieve **30, 60, 90 and 120 minutes integrity** are detailed on page 2 of this certificate.



First Issued: 22 December 2011
Reissued: 9 December 2021
Valid to: 21 December 2026
Issue No: 6

A handwritten signature in black ink that reads 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification

Page 1 of 2



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.

Certificate number: FRTD 427

The production of fire resistance timber doorsets are manufactured in accordance with assessment/ test reports referenced within the following table:

Doorset Description	Fire Rating	Assessment/Test Report
Strebord	FD30	Chilt/A02066 IFCA/08037
Strebord	FD60	Chilt/A02067 IFCA/08038
Stredor	FD30	CNA/F15159
Stredor	FD60	WF377027
Warm Springs Composite Products	FD60, FD90 & FD120	IFCA / 07019
LUX	FD30	PAR/20276/01

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

It is the certificates holder’s responsibility to ensure that the latest version/revision of the above assessment/test reports are maintained as part of the audited FPC system.

Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.