



# FIRE RESISTANT TIMBER FIRE DOORS

**Certificate number: FRTD480a**

Certificate only valid if verified on website - [www.ifccertification.com](http://www.ifccertification.com)

This is a product certificate to certify that

***United Wood Products Co. Ltd.***

PO Box 240  
Riyadh - 11383  
Kingdom of Saudi Arabia

Tel: +966(1)265 7777

Fax: +966(1)2652177

E-mail: [fm@uwpc.com](mailto:fm@uwpc.com)

Who fabricate the following fire doors:

**UWPCO BS FD30      UWPCO BS FD60  
UWPCO BS FD90**

have satisfied the requirements of the above scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 90 minutes integrity** are detailed in the test reports referenced below.

Schedule ref: WARRES 67001, 67002, 66519



First Issued: 22 July 2013  
Re-issued: 20 October 2021  
Valid to: 21 July 2026  
Issue No: 4



175

Ian Woodhouse  
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH  
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.