



Product Certification Scheme Fire Shutters & Barriers SD06

Certificate number: FSB 411

This is a product certificate to certify that

Coopers Fire Ltd

Ignis House, Houghton Avenue
Waterlooville, Hampshire
PO7 3DU

who fabricate the following product:

***FIREMASTER™ Fire Barrier
Uninsulated Drop Curtain***

have satisfied the requirements of the above scheme. This includes the initial type testing of products to **BS476: Part 22** and **EN1634-1**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve **240 minutes to BS 476: Part 22** and **120 minutes integrity to EN1634-1** are detailed in the schedules referenced below.



Schedule ref: FSB/411/S04 & S05
First Issued: 17 January 2006
Reissued: 31 March 2016
Revised: 10 September 2020
Valid to: 20 April 2021
Issue No: 7



175

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.

F27 ©IFC Certification Ltd 2004