



FIRE RESISTANT TIMBER DOOR SCHEME

Certificate number: FRTD462

Certificate only valid if verified on website - www.ifccertification.com

This is a product certificate to certify that

Takis C Marangos & Sons Ltd

Agios Athanasios Industrial Estate
P.O.Box 54676,
CY-3726 Limassol
Cyprus

Telephone: +357 25724085/6 Fax: +357 25721208
E-mail: info@takismarangos.com

Who fabricate the following timber fire doors and or doorsets:

Halspan FD30
Halspan FD120

Halspan FD60
Strebord FD30

Halspan FD90
Strebord FD60

have satisfied the requirements of the IFCC SDP01 Timber Door scheme. This includes the testing of products to **BS476: Part 22**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below.

Schedule Nos: HS01, HS02, HS03, HS04,
HS05, HS06, SS01, SS02



First issued: 23 October 2009
Reissued: 21 October 2022
Valid to: 22 October 2023



Issue No. 9

175

Ian Woodhouse
Director of Certification

IFC Certification Ltd
20 Park Street, Princes Risborough, Buckinghamshire. England HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.