

## Schedule for:

### ***Kete S.A.***

Industrial Area of Polykastro,  
Kilkis 61200  
Greece

Tel: 00302343020280

Product Name	Configuration	Rating (Integrity)	Test Report Ref
ESTIA	Single leaf	EI230	09/2018
Symmetrico	Single leaf	EI60	02/2013
Symmetrico	Single Leaf	EI120	06/2012
Symmetrico	Double Leaf	EI60	01/2013
Symmetrico	Double Leaf	EI120	05/2012
SECURITY FIRE PROOF DOORS REI 90	Single Leaf	EI120	07/32303135 M1 (Door A Only)
Symmetrico REI90	Single Leaf Glazed	EI90	06/32300776M1

The Schedule forms an integral part of the certification specifying the scope and field of application for the doors including the configurations, leaf sizes and infills approved together with the hardware, seal and frame specifications which must comply with the doorset as tested in test numbers 09/2018, 01/2013, 02/2013, 05/201207/32303135 M1 (Door A Only) & 06/32300776M1.

Only doors manufactured in accordance with this Schedule complying with the details of test numbers 01/2013, 02/2013, 05/201207/32303135 M1 (Door A Only) & 06/32300776M1 are deemed to be covered by the certification.

This schedule must be read in conjunction with the above-mentioned test reports and all aspects of the specification and limitations defined therein must be satisfied. Failure to comply with all specifications will invalidate the approval and may jeopardise the fire performance.



**Ian Woodhouse**  
Certification Director

**Date: 22 August 2018**  
**Revised: 27 February 2020**

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.

©IFC Certification Ltd