



FIRE RESISTANT TIMBER DOOR SCHEME

Certificate number: IFCC 1605

Certificate only valid if verified on website - www.ifccertification.com

This is a product certificate to certify that

John Loughnane & Sons Joinery Works Limited

Monivea, Athenry
Co Galway
H65 PV25
Ireland
Tel: +35 391849024

Who fabricate the following timber fire doors and or doorsets:

Strebord FD30, FD60, FD90, FD120
Halspan FD30, FD60, FD90, FD120

have satisfied the requirements of the SDP01 Fire Resistant Timber Door scheme. This includes the testing of products to **BS476: Part 22** the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed on page 2 of this certificate.



Initial certification: 14 October 2020

Revised: 20 April 2021

Valid to: 13 October 2025

Issue status: 1

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification
Page 1 of 2



175

IFC Certification Ltd
20 Park Street, Princes Risborough, Buckinghamshire. England HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.

Certificate number: IFCC 1605

The production of fire resistance timber doorsets are manufactured in accordance with assessment/ test reports referenced within the following table:

Doorset Description	Fire Rating	Assessment/Test Report
Strebord	FD30	IFCA/08037 & Chilt/A02066
Strebord	FD60	IFCA/08038 & Chilt/A02067
Warmssprings	FD60, FD90, FD120	IFCA/07019
Fibrecore	FD60	PAR/14658/01
Trisound	FD30	PAR/12033/01
Trisound	FD60	PAR/13088/01
Ramkor	FD90	PAR/17082/01
Halspan 30 Prima Inc Prima Plus	FD30	FEA/F97174
Halspan 60 Prima Inc Prima Plus	FD60	FEA/F96103
Halspan 30 Prima Panelled	FD30	FEA/F97097
Halspan 60 Prima Panelled	FD60	CHILT/A01015
Halspan Optima 30	FD30	CHILT/A01204
Halspan Optima 60	FD60	FEA/F01205
Halspan 90	FD90	CHILT/A05151
Halspan 120	FD120	BMT/CNA/F15082
Halspan Prima Plus	FD90	WF389581
Halspan Prima Plus	FD120	WF389580

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

It is the certificate holder's responsibility to ensure that the latest version/revision of the above assessment/test reports are maintained as part of the audited FPC system.

Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.