



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC 1664

Certificate only valid if verified on website - www.ifccertification.com

This is a product certificate to certify that

Amjaad Engineering & Contracting LLC

Ghala Al Sanaiah/Bousher
PO BOX 1306
Postal Code 130
Sultanate Of Oman
Muscat

Telephone No. 009 2459 710

Who fabricate the following timber fire doors and or doorsets:

Kingsa FD30 Kingsa FD60 Kingsa FD90 Kingsa FD120

Strebord FD30 Strebord FD60 Ramkor FD90 Ramkor FD120

have satisfied the requirements of the SDP01 Timber Fire Door scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below.

Schedule ref: KS01, KS02, KS03, KS04, SS01, SS02, RA01, RA02



First Issued: 09 September 2021
Valid to: 08 September 2026
Issue No: 1

Ian Woodhouse
Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.