



# FIRE RESISTANT TIMBER FIRE DOORS

**Certificate number: IFCC 1721**

*Certificate only valid if verified on website - [www.ifccertification.com](http://www.ifccertification.com)*

This is a product certificate to certify that

## **Unity Doors Limited**

Unit 1, Newent Business Park,  
Newent  
Gloucestershire  
GL18 1DZ  
Tel. 01531 822585

Who fabricate the following timber fire doors and or doorsets:

## **Firesafe Timber Composite EI30 Sa**

have satisfied the requirements of the SDP01 Timber Fire Doors scheme. This includes the testing of products to **EN1634-1 and EN1634-3**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve **30 minutes integrity and insulation** are detailed in the reports referenced on page 2.



First Issued: 11 April 2022

Revised: 09 June 2022

Valid to: 10 April 2027

Issue No: 2

Ian Woodhouse  
Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. HP27 9AH, UK  
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.

**Certificate number: IFCC 1721**

The fire resistant timber doorsets are manufactured in accordance with assessment/ test reports referenced within the following table:

<b>Doorset Description</b>	<b>Fire Rating</b>	<b>Classification/Extended Application Report</b>
Single Leaf Timber Composite	EI30 Sa	ERF-20-000575 RC Rev 1
Single Leaf Timber Composite	EI30 Sa	EFR-20-000575 EXAP Rev 1

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

**It is the certificate holder's responsibility to ensure that the latest version/ revision of the above assessment reports are maintained as part of the audited FPC system.**

**Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.**