



## FIRE RESISTANT TIMBER FIRE DOORS

***Certificate number: IFCC 1754***

*Certificate only valid if verified on website [www.ifccertification.com](http://www.ifccertification.com)*

This is a product certificate to certify that

***Artwood Group S.A.L***

Sin El-Fil  
Al Qalaa  
Naoum Moukarzel Street  
Lebanon  
Telephone no. +961 (0)1 485401

Who fabricate the following timber fire doors and or doorsets:

**Halspan EI30                      Halspan EI60**

have satisfied the requirements of the SDP 01 Fire Resistant Timber & Wood Based Door scheme. This includes the testing of products to **EN1634-1**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and extended application report to achieve from **30 minutes to 60 minutes integrity** are detailed in the schedules referenced below.

Schedule ref: BMT/CAN/F13020, BMT/FEA/F13021



First Issued: 31 August 2022  
Valid to: 30 August 2027  
Issue No: 1

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse  
Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH  
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.