



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC 1037

Certificate only valid if verified on website - www.ifccertification.com

This is a product certificate to certify that

Michalis D Pikoulis & SIA E.E (IntraDoor)

2nd Kilometer New Kios
Nafplio
Argos 21200 Greece
Tel: + 30 2751 051392

who fabricate timber fire doors with timber or steel frames:

Halspan FD30/FD30S	Halspan FD60/FD60S	Halspan FD90/FD90S
Halspan FD120/FD120S	Strebord FD30/FD30S	Strebord FD60/FD60S
Moralt FD30/FD30S	Moralt FD60/FD60S	Moralt FD90/FD90S

have satisfied the requirements of the scheme SDP01. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed on page 2 of this certificate.



First Issued: 10th September 2013
Reissued: 4th October 2021
Revised 9th December 2021
Valid to: 9th September 2022
Issue No: 11



175

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

Page 1 of 2

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.

Certificate number: IFCC 1037

The production of fire-resistant timber doorsets are manufactured in accordance with assessment/ test reports referenced within the following table:

Description	Fire Rating	Assessment/ Test Report
Halspan Prima	FD30	IFCA06166 (HS01)
Halspan Prima	FD60	IFCA06167 (HS02)
Halspan Optima	FD30	PAR/10341/01 (HS03)
Halspan Optima	FD60	PAR/10341/02 (HS04)
Halspan	FD90	PAR/10513/01 (HS05)
Halspan	FD120	PAR/10513/02 (HS06)
Strebord	FD30	IFCA/08037 (SS01)
Strebord	FD60	IFCA/08038 (SS02)
Moralt Firesound	FD30 / FD60	WF409922
Moralt Firesound	FD90	WF409923

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

It is the certificate holder's responsibility to ensure that the latest versions / revisions of the above assessment reports are maintained as part of the audited FPC system.

Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.