



FIRE RESISTANT STEEL DOOR

Certificate number: IFCC 1081

This certificate certifies that the product below
manufactured by

Fitzpatrick s.a.l.

Meker Building – Industrial City
Nahr El Mott
Beirut
Tel no.: +961 1 901888

Fitzpatrick Steel Lath Roller Shutter

Satisfy the requirements of the SDP02 Metal Fire Door scheme. This includes the testing of products to **BS476-22: 1987**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 240 minutes integrity** are detailed in the schedules referenced below.

Schedule ref: IFCC 1081/S01



First Issued: 9 April 2014
Re-issued 17 September 2019
Valid to: 8 April 2024
Issue No: 3



175

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.