



FIRE RESISTANT STEEL FIRE DOORS SDP02

Certificate number: IFCC1119

This is a product certificate to certify that

Al Salem for Wrought Iron

P.O. Box 22308

Doha

Qatar

Email: elsalem.steel@gmail.com

Tel/Fax no.: +974 445 10205

Mobile: +974 559 09304

Who fabricate the following fire doors:

Steel Fire Door FD240

have satisfied the requirements of the above scheme. This includes the testing of products to **BS476: Part 22**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve **240 minutes integrity** are detailed in the test report referenced below.

Test report ref: NK33

First Issued: 18 December 2014

Reissued: 24 December 2019

Revised: 01 April 2020

Valid to: 17 December 2024

Issue No: 4



175

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. HP27 9AH, UK
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.