



# FIRE RESISTANT TIMBER FIRE DOORS

**Certificate number: IFCC 1225**

*Certificate only valid if verified on website - [www.ifccertification.com](http://www.ifccertification.com)*

This is a product certificate to certify that

***Rezaik Abdullah Al Gedrawi***

Al Steen Street,  
North El-Mahkama El Kobr  
Al-Khair Blaza Center  
P.O. Box 96475, Jeddah  
Saudi Arabia

+966 012 619745

Who fabricate the following timber fire doors and or doorsets:

**Halspan  
FD30**

**Halspan  
FD60**

**Halspan  
FD90**

**Halspan  
FD120**

have satisfied the requirements of the SDP01 Timber Fire Doors scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below.

Schedule ref: HS01 - HS06



First Issued: 08 Feb 2016

Reissued: 03 Sept 2021

Valid to: 07 Feb 2026

Issue No: 2

Ian Woodhouse

Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. HP27 9AH, UK  
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.