



FIRE RESISTANT TIMBER FIRE DOORS SDP01

Certificate number: IFCC1246

Certificate only valid if verified on website - www.ifccertification.com

This is a product certificate to certify that

Mondo Porta

Malesina, Lokridos,
35001
Greece

Tel: +30 2233051044

Who fabricate the following timber fire doors and or doorsets:

**Halspan FD30S, Halspan FD60S, Halspan FD90, Halspan FD120
Strebord FD30S, Strebord FD60S, Strebord FD90 Trisound FD30
Trisound FD60**

have satisfied the requirements of the above scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below.

Schedule ref: HS01-HS06, SS01-SS03, PAR/12033/01, PAR/13088/01



First Issued: 01 July 2016
Reissued 28 June 2021
Valid to: 30 June 2022
Issue No: 4

A handwritten signature in black ink, appearing to read 'Ian Woodhouse'.

Ian Woodhouse
Director of Certification



175

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. HP27 9AH, UK
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: info@ifccertification.com Web: www.ifccertification.com
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.